

## Acoustical Firedoor Core System

### Manufacturer

Georgia-Pacific Gypsum LLC  
133 Peachtree Street  
Atlanta, GA 30303

Georgia-Pacific Canada LP  
2180 Meadowvale Boulevard, Suite 200  
Mississauga, ON L5N 5S3

Technical Service Hotline: 1-800-225-6119

### Product Description

**Georgia-Pacific Gypsum's acoustical firedoor component systems** combine a patent pending 3-ply acoustical mineral core with FireDefender® FS-II plus Edge Banding Components. Door assemblies built using Georgia-Pacific acoustical mineral cores and fire rated flush door components carry a positive pressure/neutral pressure rating of up to 45-minutes and were tested in accordance with NFPA 252 (2008), UL 10C (2009), CAN4 S104 (1985), and are listed by Warnock Hersey (Intertek Testing Services). Sound Transmission Class (STC) ratings of 37 to 40 were achieved with these door assemblies. The sound testing was conducted at Architectural Testing and Riverbank Acoustical Laboratories (RAL) on operable door assemblies in accordance with ASTM E-90 (2009), ASTM E 413-04, ASTM E 1332-90, and ASTM E 2235-05.

### Parameters

• Maximum Door Sizes	Fire Rated: 3/0 7/0 single swing; Sound Rated: 3/0 7/0 single swing
• Maximum Fire Rating	45-minute positive pressure
• Temperature Rise	250° F at 30 minutes
• Minimum Core Thickness	1-1/2"
• Latchsets	Cylindrical with maximum 5" backset
• Bolts	Surface mounted
• Fire Exit Devices	Surface mounted vertical rods and rim type fire exit devices
• Door Closers	Surface mounted
• Door Bottoms	Fully mortised
• Vision Panels	Maximum 100 sq. in.

### Physical Properties

Two core configurations are shown below:

#### GP 39 STC, 45 min. fire

Property	Sample Size
Core Weight, nominal (lbs./sq. ft.)	6.7
3/0 7/0 Door Weight, nominal (lbs./sq. ft.)	8.3
Flexural Strength, (lbs.), (GP method, references ASTM C 473, Method B)	>80 6" x 16"
MOR (psi)	>125 6" x 16"
Compressive Strength, (psi) (GP method, references ASTM C 472)	>500 4" x 4"
Tensile IB, (psi) Outer Plies (ASTM D 103)	>26 2" x 2"
Screwholding, (lbs.) Door Face Unblocked (WDMA TM-10)	<400* 1" x 3"

\* Blocking or thru-bolts are recommended for operable door hardware.

### Submittal Approvals

Job Name \_\_\_\_\_  
Contractor \_\_\_\_\_  
Date \_\_\_\_\_

#### GP 40 STC, 45 min. fire

Property	Sample Size
Core Weight, nominal (lbs./sq. ft.)	9.0
3/0 7/0 Door Weight, nominal (lbs./sq. ft.)	9.7
Flexural Strength, (lbs.), (GP method, references ASTM C 473, Method B)	>125 6" x 16"
MOR (psi)	>195 6" x 16"
Compressive Strength, (psi) (GP method, references ASTM C 472)	>500 4" x 4"
Tensile IB, (psi) Outer Plies (ASTM D 103)	>40 1" x 3"
Screwholding, (lbs.) Door Face Unblocked (WDMA TM-10)	>550 1" x 3"

### Vision Panels

100-sq. inches maximum visible area. Anemostat LoPro IS Vision Kit with 19 mm (3/4") Pyrostop Glazing. Listed and labeled intumescent used around the perimeter of the vision kit.

### Hardware

Hinges per NFPA 80, Table 2-8.1-1, listed continuous hinges, spring hinges, and invisible hinges. Cylindrical latches. Listed and labeled mortised or surface mounted door bottoms. Surface mounted closers.

### Sound Performance

GP 39-45 and GP 40-45 sound deadening cores used in sound testing were constructed with 1-1/2" FireDefender FS-II top rail and 1" stiles. The bottom rail of the door was constructed of FS-I and housed a fully mortised door bottom. Standard hardware was used which consisted of a cylindrical lock and heavy duty full mortised hinges. Doors were tested with and without vision panels, LoPro IS metal vision frame with 19 mm Pyrostop Glazing. The perimeter of the door was equipped with perimeter sealing devices and housed a fully mortised door bottom.

Please see test reports on reverse.

**Changes in sound ratings could be expected if alterations or deviations occur from the door construction or hardware configuration described above.**

**Acoustical Tests**

GP Acoustical Core	Operable STC	OITC	Seal System Used In Testing	Referenced Sound Transmission Loss Test
GP 39-45	39	35	Seal Set #1	Architectural Testing Report 99297.01-113-11
	37	34	Seal Set #2	Architectural Testing Report 99297.01-113-11
	38		Seal Set #3	RAL-TL09-347
GP 40-45	40	36	Seal Set #1	Architectural Testing Report 99297.01-113-11
	38		Seal Set #4	RAL-TL09-345

Seal Systems	Perimeter Seals	Door Bottom	Threshold
Seal Set #1	Zero 475 + 119WB	Zero 369	none
Seal Set #2	Zero 475	Zero 369	none
Seal Set #3	2 rows of NGP 5050	NGP 321V	NGP 950S
Seal Set #4	2 rows of NGP 5050 + 1071 SA	NGP 425N	NGP 950S



**SALES INFORMATION AND ORDER PLACEMENT**

*Sales* Steve Brown **404-652-2518**  
**stdbrown@gapac.com**

*Order Placement* Corine Chambers **573-885-0343**  
**cachambe@gapac.com**

**TRADEMARKS** FIREDEFENDER and the GEORGIA-PACIFIC logo are owned by or licensed to Georgia-Pacific Gypsum LLC.

**WARRANTIES, REMEDIES AND TERMS OF SALE** For current warranty information for this product, please go to [www.gpgypsum.com](http://www.gpgypsum.com) and select the product for warranty information. All sales of this product by Georgia-Pacific are subject to our Terms of Sale available at [www.gpgypsum.com](http://www.gpgypsum.com).

**UPDATES AND CURRENT INFORMATION** The information in this document may change without notice. Visit our website at [www.gpgypsum.com](http://www.gpgypsum.com) for updates and current information.

**CAUTION** For product fire, safety and use information, go to [www.gp.com/safetyinfo](http://www.gp.com/safetyinfo).

**HANDLING AND USE – CAUTION** Sanding, machining or abrading this product after drying may generate dust which can irritate eyes, nose, throat, skin and upper respiratory tract. Use wet sanding to minimize dust generation and always maintain proper ventilation in the work area. Avoid breathing dust and minimize

contact with skin and eyes. Wear long sleeve shirts, long pants and eye protection. Use a dust mask or NIOSH/MSHA approved respiratory protection while sanding, machining and during clean-up as appropriate. For additional product fire, safety and use information go to [www.gp.com/safetyinfo](http://www.gp.com/safetyinfo) or call 1-800-225-6119.

**FIRE SAFETY CAUTION** Passing a fire test in a controlled laboratory setting and/or certifying or labeling a product as having a one-hour, two-hour, or any other fire resistance or protection rating and, therefore, as acceptable for use in certain fire rated assemblies/systems, does not mean that either a particular assembly/system incorporating the product, or any given piece of the product itself, will necessarily provide one-hour fire resistance, two hour fire resistance, or any other specified fire resistance or protection in an actual fire. In the event of an actual fire, you should immediately take any and all actions necessary for your safety and the safety of others without regard for any fire rating of any product or assembly/system.